

SECTION 10505
Rebel 16 Athletic Lockers

PART 1 – GENERAL

1.01 RELATED DOCUMENTS

- A. Drawings and general provisions of the Contract, including General and Supplementary Conditions and Division 1 specifications apply to this section.

1.02 SUMMARY

- A. This Section includes the following:
 - 1. REBEL16 Athletic Lockers, including the following:
 - a. Single Tier (48", 60" or 72" OH)
 - b. Double Tier (48", 60" or 72" OH)
 - c. Three Tier (60" or 72" OH)
 - d. Five Tier (60" OH)
 - e. Six Tier (72" OH)
 - f. Six-Two-Six Configuration (72" OAH)
 - 2. Widths: 12", 15", 18", 24"
 - 3. Depths: 12", 15", 18", 24"
 - 4. Provide fasteners and anchorage devices to install lockers provided under this section.
 - 5. Provide metal filler panels to fill between banks of lockers and adjacent construction.

1.03 SUBMITTALS

- A. Product Data: Include construction details, material descriptions, dimensions of individual components and profiles, and finishes for each type of locker and bench.
- B. Shop Drawings: Show lockers in detail, method of installation, fillers, trim, base, and accessories. Include locker numbering sequence information.
- C. Samples for verification: Submit one full-size locker sample for evaluation. Adherence to the specification is required. Locker submitted must meet specification regardless of manufacturer's standard product. Submit manufacturer's technical data and installation instructions for metal locker units.
- D. Maintenance Data: For adjusting, repairing and replacing locker doors and latching mechanisms to include in maintenance manuals specified in Division 1.

1.04 QUALITY ASSURANCE

- A. Uniformity and Single Manufacturer Requirements: Provide each type of metal locker as produced by a single USA manufacturer, including necessary mounting accessories, fittings, and fastenings.
- B. All of the locker products in this specification as well as all of the materials used to manufacture this product to be produced in the United States of America. No exceptions will be allowed.

- C. Installers Qualifications: Lockers to be installed by an experienced agent of the manufacturer.

1.05 DELIVERY, STORAGE, AND HANDLING

- A. Packing and Shipping: Do not deliver metal lockers until building is enclosed and ready for locker installation.
- B. Storage and Protection: Protect materials from damage during delivery, handling, storage and installation.

1.06 WARRANTY

- A. Locker manufacturer shall warrant the lockers for the lifetime use of the original purchaser from date of shipment. Warranty shall include all defects in material and workmanship, excluding finish, vandalism and improper installation.

PART 2 – PRODUCTS

2.01 MANUFACTURERS

- A. Acceptable Manufacturers: Subject to compliance with requirements of the Contract Documents, acceptable USA manufacturers are as follows:
 - 1. DeBourgh Manufacturing Company

2.02 FABRICATION

- A. Locker Construction
 - 1. Lockers to be welded unibody construction with exposed welds sanded smooth.
 - 2. No bolts, screws or rivets used in assembly of locker units.
 - 3. Ship lockers ready to be anchored in place in accordance with manufacturer's instructions.
- B. Body of Lockers
 - 1. Tops, Bottoms, Sides: Constructed of 16 Ga domestic Cold Rolled Steel (CRS) for maximum durability.
 - 2. Backs: Solid sheet of 18 Ga CRS welded to frames of sides and intermediate partitions.
 - 3. Shelves: Constructed of 16 Ga CRS welded to sides and intermediate partition construction. Shelves provided in lockers 60 inches and taller, located to provide a minimum of 15-inch clearance from top of locker.
 - 4. Tier Dividers: Full depth CRS securely welded on all four sides, to combine with tops, bottoms, sides, and intermediate partitions.
- C. Continuous Door Strike
 - 1. Tier dividers, tops and bottoms constructed to provide two-sided, continuous door strike on both hinge and latch sides for a secure, sanitary and intrusion-free locker while door is in closed position.
- D. Doors
 - 1. Doors are 14 Ga CRS formed outer panel with double bends on both sides and a single bend on top and bottom.
 - 2. Doors to have 18 Ga steel formed stiffener panel securely welded inside the door to form a reinforced channel for additional torque-free strength and sound

reduction when closing door. *Door stiffeners not included on doors with multi-point latching unless specifically requested.*

E. Door Ventilation

1. Louvers at top and bottom of door.
2. Diamond perforation
3. Solid door, no punched or cut ventilation required.

F. Intermediate Partition Ventilation

1. Solid
2. Diamond perforation

G. Latching

1. Sentry I Three-Point Three-Sided Turn Handle

- a. Latching mechanism operated by a steel handle welded to a three-point cremone type assembly.
- b. Latching rods, 3/8-inch diameter, engage top and bottom edge of locker frame. A 3/16-inch-thick center latch engages door jamb.

OR

2. Sentry II Recessed Gravity Latch:

- a. Door containing stainless steel cup recessed into formed door (doors 18 inches and higher).
- b. 12 Ga steel finger lift mechanism.
- c. Spring activated nylon slide latch enclosed in steel latch channel allows closing of door while padlock or built-in lock is in position
- d. Rubber bumpers riveted to door stops for silent operation

OR

3. Sentry III Single-Point Latch

- a. Eleven-gauge stationary latch welded securely to locker frame.
- b. Latch extends no more than 1/4-inch into locker openings, penetrating through cup.
- c. Flush-mounted, recessed stainless steel cup in a formed door with 18 Ga vertical back panel stiffener.

H. Hinges

1. 16 Ga continuous piano hinge on the right side of the opening.
 - a. Hinges welded to door and riveted to locker frame.

OR

2. Three inch, five knuckle, 14 Ga heavy-duty fast pin welded to both door and frame.

I. Slope Tops

1. Provide 20 Ga CRS continuous slope tops with approximately 18-degree slope. Join slope panels with splice joints and finish locker runs with 16 Ga slope top end caps.

OR

2. Provide 18 Ga all welded slope top with 25-degree pitch, attached at factory with concealed fasteners. Slope top to be in addition to standard 18 Ga flat top. OR

J. Closed Bases

1. Provide 4-inch-high Z-base sections from 16 Ga formed CRS. Securely fasten Z-base to floor and lockers to Z-base.
- OR**
2. Provide 4-inch-high, 14 Ga welded steel base enclosed on all four sides securely welded to locker bottom.
- K.** Filler Panels: Manufacturer's standard fabricated from 18 Ga solid steel finished to match lockers. Filler available in manufacturer's standard sizes.
- L.** Finish:
1. Complete locker unit to be thoroughly cleaned, phosphatized and sealed.
 2. Finish to be baked powder coat with a minimum 2-3 mil thickness.
 3. As selected from manufacturer's standard offering.

2.03 LOCKER ACCESSORIES

A. Hooks

1. Hooks to be heavy duty forged steel with ball ends and zinc plated.
2. Provide one double ceiling hook in each locker opening.

B. Numbering

1. Furnish each locker with black anodized laser-etched aluminum number plate.
2. Locate number plate near center of each door.
3. Owner to furnish numbering sequence.

PART 3 – EXECUTION

3.01 INSTALLATION

A. Wall Installation

1. Securely anchor every locker to wall and/or floor before use.
2. Anchoring to be determined by conditions at time of installation.
3. Install the adjacent locker units by bolting at four points, two at top and two at bottom, using 1/4-inch cadmium plated bolts.

3.02 ADJUSTING

- A.** General Requirements: Upon completion of installation, inspect lockers and adjust for proper door and locking mechanism operation.

3.03 CLEANING

A. General Requirements

1. Clean interior and exposed exterior surfaces, removing debris, dust, dirt, and foreign substances on exposed surfaces.
2. Touch up scratches and abrasions to match original finish.
3. Polish stainless steel and non-ferrous metal surfaces.
4. Replace locker units that cannot be restored to factory-finished appearance.
5. Use only materials and procedures recommended or furnished by locker manufacturer.